

**Town of Hinesburg Water Use Ordinance**

**Appendix E Annual Allocation Pool Designations**

Annual Allocation Pool Designations Form

The following water allocation pool designation were made and approved by the Board for the period:

**September 17, 2018 to June 30, 2019**

Net Water Capacity: 215 gallons per minute (GPM)  
 Water Capacity as gallons per day: 215 x 900 =193,500 gallons per day (GPD)  
 Actual Water Use (01/24/2018 through 05/31/2018): 130,316 GPD  
 Remaining Capacity: 63,184 GPD  
 Approved Residential Allocations (unconnected): 13715 GPD  
 Approved Enterprise Allocations (unconnected): 8173 GPD  
 Reserve (@ 7.2% permitted capacity): 13932 GPD  
 Allocable capacity: 27,364 gallons per day

**Category 1 requirement**

Municipal, Educational, Institutional, Special Projects - Minimum of 5,000 Gallons per Day (GPD) or all remaining Uncommitted Reserve Capacity, whichever is less

Total GPD	Residential	Enterprise
7,500		

**Category 2 requirement**

Projects in the village core defined as the Village District, the Commerce Street portion of the Commercial District, Industrial Districts 3 and 4 - Minimum of 5,000 GPD or all remaining Uncommitted Reserve Capacity, whichever is less

Total GPD	Residential	Enterprise
10,000	7500	2500

**Category 3**

Projects in all other zoning districts of the water service area including Village Northeast, Village Northwest, All remaining Commercial districts, Industrial 5, Residential 1, and Residential 2

Total GPD	Residential	Enterprise
9864	5040	4824

Or

District	Total GPD	Residential	Enterprise
Village Northeast			
Village Northwest			
Commercial			
Industrial 5			
Residential 1			
Residential 2			

Board of Commissioners Chair: \_\_\_\_\_ Date: September 17, 2018