

Town of Hinesburg Water Use Ordinance

Appendix E Annual Allocation Pool Designations

Annual Allocation Pool Designations Form

The following water allocation pool designation were made and approved by the Board for the period:

September 17, 2018 to June 30, 2019

Net Water Capacity: 215 gallons per minute (GPM)
 Water Capacity as gallons per day: 215 x 900 =193,500 gallons per day (GPD)
 Actual Water Use (01/24/2018 through 05/31/2018): 130,316 GPD
 Remaining Capacity: 63,184 GPD
 Approved Residential Allocations (unconnected): 13715 GPD
 Approved Enterprise Allocations (unconnected): 8173 GPD
 Reserve (@ 7.2% permitted capacity): 13932 GPD
 Allocable capacity: 27,364 gallons per day

Category 1 requirement

Municipal, Educational, Institutional, Special Projects - Minimum of 5,000 Gallons per Day (GPD) or all remaining Uncommitted Reserve Capacity, whichever is less

Total GPD	Residential	Enterprise
7,500		

Category 2 requirement

Projects in the village core defined as the Village District, the Commerce Street portion of the Commercial District, Industrial Districts 3 and 4 - Minimum of 5,000 GPD or all remaining Uncommitted Reserve Capacity, whichever is less

Total GPD	Residential	Enterprise
10,000	7500	2500


Category 3

Projects in all other zoning districts of the water service area including Village Northeast, Village Northwest, All remaining Commercial districts, Industrial 5, Residential 1, and Residential 2

Total GPD	Residential	Enterprise
9864	9500	364

Or

District	Total GPD	Residential	Enterprise
Village Northeast			
Village Northwest			
Commercial			
Industrial 5			
Residential 1			
Residential 2			

Board of Commissioners Chair:  Date: November 19, 2018